

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY REGION 10

1200 Sixth Avenue, Suite 900 Seattle, Washington 98101-3140

MAY 3 0 2014

OFFICE OF COMPLIANCE AND ENFORCEMENT

Reply To: OCE-133

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Tracy Gilchrist
Denver Service Center -NPS
Design and Construction
12795 West Alameda Parkway
Lakewood, Colorado 80228-2838

Re:

February 5, 2014, NPDES Compliance Inspection

NPDES Permit No. WA0026662

Dear Mr. Gilchrist:

On February 5, 2014, the U.S. Environmental Protection Agency (EPA) inspected the U.S. Department of the Interior, Bureau of Reclamation's Elwha Water Treatment Plant (EWTP) located in Port Angeles, Washington, to determine its compliance with the Clean Water Act (CWA) and the EWTP's National Pollutant Discharge Elimination System (NPDES) permit, Permit No. WA0026662. I would like to express our appreciation for your company's time and cooperation during the inspection.

A review of the inspection report and EPA's files revealed the following concerns:

The inspector's review of the Discharge Monitoring Reports (DMR's) during the inspection showed that the EWTP had 24 exceedences of the maximum daily limit for total suspended solids (TSS) since the permit effective date of August 1, 2009.

The inspector also noted that a new diversion pump station was recently constructed at the facility. This change in the facility's operation must be added to the facility's best management practices (BMP) plan. Section II.6.a. of the permit, requires that "the permittee must amend the BMP Plan whenever there is a change in the facility or in the operation of the facility which materially increases the generation of pollutants or their release or potential release to surface waters." For any questions about this change or the facility's BMP Plan, contact the EPA permit writer for this facility, Brian Nickel, at (206)-553-6251.

At the time of the inspection, the inspector observed that both the 2012 and 2013 Annual Receiving Water Monitoring Reports had not been submitted along with the January DMR for the following year as required by Section I.C.5. of the permit. In addition, the ETWP's quality assurance plan (QAP) did not have a documented map or description of the location of each sampling point, as required by Section II.A.3. of the permit. Tom Hubbard submitted the two Annual Receiving Water Monitoring Reports to

the EPA and updated the QAP immediately following the inspection. Thank you for your prompt responses to these matters.

Although it is EPA's goal to ensure NPDES facilities comply fully with their permits, the ultimate responsibility rests with the facility. We strongly encourage facilities to maintain full knowledge of the applicable NPDES requirements and other appropriate statutes, and to take all appropriate measures to ensure compliance.

If you have any questions regarding this letter or other matters related to your compliance with your NPDES permit or the CWA, please contact Dustan Bott, Compliance Officer, at (206) 553-5502.

Sincerely,

Jeff KenKnight, Manager NPDES Compliance Unit Express Mail

Return Receipt for Merchandise

C.O.D. Yes COMPLETE THIS SECTION ON DELIVERY Restricted Delivery? (Extra Fee) 9536 Received by (Printed Name) 유무나로 D. Is delivery address Service Type
Certified Mail
Registered
Insured Mail ELlebel E000 Domestic Return Receipt U.S. Postal Service 0870 so that we can return the card to you. Attach this card to the back of the mailpiece, 12795 West Alameda Parkway Print your name and address on the reverse Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Denver Service Center - NPS 9002 16 -akewood, CO 80228-2838 SENDER: COMPLETE THIS SECTION Design and Construction 0003 Return Receipt Fee PS Form 3811, February 2004 Mr. Tracy Gilchrist 0870 (Transfer from service labe Mr. Tracy Gilchrist Denver Service Center - NPS Total Postage & 7006 Design and Construction Article Number 12795 West Alameda Parkway Lakewood, CO 80228-2838 or PO Box No.

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Tracy Gilchrist
Denver Service Center -NPS
Design and Construction
12795 West Alameda Pkwy
Lakewood, CO 80228-2838

Re: February 5, 2014, NPDES Compliance Inspection

NPDES Permit No. WA0026662

If you have any questions regarding this letter or other matters related to your compliance with your NPDES permit or the CWA, please contact Dustan Bott, Compliance Officer, at (206) 553-5502.

Sincerely,

Jeff KenKnight, Manager NPDES Compliance Unit

N:\APPS\OCE\NPDES Compliance\Bott\Elwha WTP US DOI, BOR

		CONCURRENCES	
Initials:	TOB		
Name:	Bott		
Date:	5/28/14		